


# Smoke and Dye Testing Summary

## High Level Sewershed

### Run Summary

Test ID	Test Type	Date Inspected	Company / Super.	Blower MH	Ground Condition	Notification Made?	Total Length
S1028-088	Smoke	9/12/2008	ADS/TM	S13AA1003MH	Dry	Yes	1,261.01



---

# Smoke and Dye Testing Summary

---

## High Level Sewershed

### Run Summary

Test ID	Test Type	Date Inspected	Company / Super.	Blower MH	Ground Condition	Notification Made?	Total Length
S1028-088	Smoke	9/12/2008	ADS/TM	S13AA1003MH	Dry	Yes	1,261.01

### Isolated Pipes

Pipe ID	Upstream MH	Downstream MH	Length (ft)	Diameter (In)
S13CC1018G1	S13CC1018MH	S13AA1003MH	254.0219	22
S13AA1003G1	S13AA1003MH	S13AA1011MH	261.8389	22
S13AA1011G1	S13AA1011MH	S13YY_009MH	579.6053	21
S13AA1025G1	S13AA1025MH	S13YY_009MH	165.5463	8

### Observations & Photos

No smoke was observed during this test.

